


AS SHOWN
 DESIGN INTENT
 BOTTC
 TO BE
 12
 EXIST
 HIGH S



HUNTINGTON PLACE

" = 20'

CATCH BASIN
 RIM EL = 99.8
 DR. WAY
 160' x 20' GR.
 1120.0
 w/ 4\"/>

DO NOT BACKFILL

Designer's Name J. Shepard D-Permit No. 777 Approved for Construction No. 180120
Installer's Name M. Fritz I-Permit No. 280 Work Number 59370

NOT APPROVED FOR OPERATION (see below)

OWNER Grandmaison TOWN Hampton

- | | | |
|---|--|---|
| <input type="checkbox"/> SYSTEM NOT INSTALLED PER PLANS | <input type="checkbox"/> FILL NOT EXTENDED OR NOT ENOUGH FILL | <input type="checkbox"/> NOT ENOUGH PITCH ON LINE TO TANK/LINE TO D-BOX |
| <input checked="" type="checkbox"/> SITE CONDITIONS NOT ACCURATELY SHOWN | <input type="checkbox"/> Fill must extend feet beyond outside limits of the leach field before tapering off at a slope. | <input type="checkbox"/> LEACH AREA INSTALLATION Stone, pipe, etc. See below. |
| <input type="checkbox"/> TOO CLOSE TO SURFACE WATER | <input type="checkbox"/> A layer of impervious soil must be placed on sloped portion of fill to prevent lateral seepage of sewage. | <input type="checkbox"/> WELL RELOCATED |
| <input type="checkbox"/> SEPTIC TANK INSTALLATION Size, location, etc. See below. | | <input type="checkbox"/> NO BUILDING STARTED |
| <input type="checkbox"/> DISTRIBUTION BOX INSTALLATION See below. | | <input type="checkbox"/> DREDGE AND FILL PERMIT MAY BE NEEDED |

COMMENTS: House different from plan provide amended plans (3 prints)
OK to Backfill Approval pending receipt of City Registry Book & Page #

PLEASE MAKE CORRECTIONS NOTED ABOVE AND CALL 431-8141

AMENDED PLANS MUST BE RECEIVED BY TIME OF INSPECTION

- ☐ System must be rebuilt in accordance with the approved plan.
- ☐ System may be approvable, as built. A licensed designer must submit a fee and (3) revised plans for an alternative design to Concord office for review and possible approval.
- ☐ System, as built, is not approvable, nor does it appear possible to reconstruct it in accordance with approved plan. An alternative design must be submitted to Concord office for review and possible approval.
- ☐ New test pits needed.
- ☐ New percolation tests needed.
- ☒ OK to backfill. System may not be used until deficiency(ies) have been corrected and an Operational Approval has been granted.

INSPECTOR Dennis W. Plante DATE 11/21/91

FOLLOW-UP DATE

19

STOCKTON SERVICES

P.O. Box 1306
HAMPTON, NEW HAMPSHIRE 03842

(603) 926-7795

To DENNIS PLANTE

Date 2/11/92
Subject AMENDED PLANS
APPL# 180120
WORK# 59370

DENNIS - I AM HANDLING PAPERWORK ON THIS FOR TOM WASSON
ENCLOSED PER HIS INSTRUCTIONS:
1) 3 PRINTS AMENDED PLAN WITH CORRECTED HSE LOCATION
2) COPY OF YOUR INSPECTION SLIP
3) APPLICATION FOR TRANSFER OF APPROVAL (INCLUDES BK & PAGE OF DEED)
TOM SAYS HE GAVE YOU THE #10 RECORDING FEE ^{W/ SITE}
CALL ME IF YOU NEED ANYTHING ELSE.
SIGNED TOMMY
☐ Please reply ☐ No reply necessary THANKS

P.O. Box 95 -- Hazen Drive
Concord, New Hampshire 03302-0095

APPLICATION FOR TRANSFER OF RSA 485-A Approval No. 180120

CIRCLE - CATEGORY (S) (Subdivision) (Construction) (Operational)

The undersigned certifies that they are the present owners of the property formerly of STANLEY BURAK and that they have read, viewed and possess the prior approvals, plans and any related conditions assigned thereto. The undersigned agrees that he will abide by the previously issued approvals. The undersigned fully understands that the system must be constructed in strict accordance with these plans and that no waivers to this Construction Approval will be allowed. Any changes will require a new submission, review and approval prior to any construction.

Our Title Reference is Book 2894 Page 0829 ROCKINGHAM Registry of Deeds and briefly is for certain land known as: LOT 3, LEACH SUBDIVISION HUNTINGTON PLACE situated in HAMPTON, New Hampshire.
Town, etc.

Transfer in Accordance with

Regulation Ws 1003.06 Eff. Sept. 5, 1984 Owner(s): NORMAN & JOYCE GRANDMAIS

Copies to:

Town Offices

Owner

WSPCD File

Original Applicant

Address (6 HUNTINGTON PLACE)
C/O TOM WASSON
PO BOX 220
HAMPTON FALLS NH
03844

Date: FEB 4, 1992

STOCKTON SERVICES

PO BOX 1306
HAMPTON, NH 03842
603/926-7795

REMITTANCE ADVICE

54-167
114

0706

CHECK
AMOUNT

PAY <u>Fifty and no/100</u>		DOLLARS	
DATE	TO THE ORDER OF	DESCRIPTION	CHECK NO.
<u>2/3/92</u>	<u>NH SOIL CONSULTANTS INC</u>	<u>amend BURAK LOT3</u>	<u>0706</u>
			\$ <u>50.00</u>

BANK MERIDIAN, N.A.
HAMPTON, NH 03842

Stanley Burak

⑈000706⑈ ⑆011401672⑆ 01 5209005⑈06



FOR WELLS INSTALLED AFTER 8/1/03

MSA 149-E-3.51 BECAME EFFECTIVE 8/26/03. THIS STATES THAT THE PROTECTIVE PS WELL RADIIUS FOR NEW WELLS SHALL NOT RESTRICT THE DEVELOPMENT OF ANY ADJUTING PROPERTY. THE STATE LAW AND REGS. THAT CAN PREVENT AN ADJUTING PROPERTY FROM INSTALLING A LEACHFIELD AS CLOSE AS 10' TO A PROPERTY LINE" IT IS VERY IMPORTANT TO LOCATE THE WELL AS SHOWN OR AT LEAST 5' FROM ANY ADJUTING PROPERTY LINE AND PS - FROM YOUR LEACHFIELD.

* EXEMPT IF ITS WITHIN 5' OF YOUR WELL.



SCHEMATIC LEACHFIELD SECTION A-A

3. _____
2. Sytco is not designed to handle discharge from a hot tub or similar.
3. Every sytco's design capacity is limited. Careful and reasonable water use is required to maximize the sytco's life.
4. Do not dispose of grease, chemicals, solvents etc. via this sytco.
5. Septic tank must be pumped by a licensed hauler at least every two years. Keep pumping receipts as proof of maintenance. Check tank yearly if sludge and surface scum exceed 1/3 of liquid depth, have tank pumped.
6. Do not allow vehicular traffic over any component of sytco unless that structure is designed to withstand an H-20 wheel load.



FOR: **STANLEY BURAK**
LOCATION **LEACH SUBDIVISION**
LOT 3
TOWN: **HAMPTON, N.H.**

NH SOIL CONSULTANTS, INC.
ONE SIMONS LANE
NEWMARKET, NH 03857
(603) 659-7231

TITLE: PROPOSED SEWAGE DISPOSAL SYSTEM